

# APPLIANCE PROFILE

Site: Bikes 'R' Us

Reference: BIKES

<b>Appliance Identity</b>		0000000001		<b>Description</b>			TOASTER			<b>Location</b>		KITCHEN											
<b>Serial Number</b>				<b>Model</b>						<b>Manufacturer</b>													
<b>Date Tested</b>		29/07/2006		<b>Test Interval</b>		52		<b>Next Test</b>		29/07/2007		<b>Last Inspection</b>				<b>Inspection Interval</b>		52		<b>Next Inspection</b>			
<b>Date of Test</b>	<b>Visual</b>	<b>Earth Bond Current</b>	<b>Earth Bond Resistance</b>	<b>Insulation Resistance</b>	<b>Flash</b>	<b>Load VA</b>	<b>Load A</b>	<b>Leakage</b>	<b>Substitute Leakage</b>	<b>Touch Leakage</b>	<b>Continuity</b>	<b>Result</b>											
29/07/2006	Pass	25.00 A	0.05 OHM	>299.90 MEG		0.70 kVA	2.90 A	0.03 mA	0.00 mA		Pass	Pass											

<b>Appliance Identity</b>		0000000002		<b>Description</b>			PHOTOCOPIER			<b>Location</b>		OFFICE											
<b>Serial Number</b>				<b>Model</b>						<b>Manufacturer</b>													
<b>Date Tested</b>		29/07/2006		<b>Test Interval</b>		52		<b>Next Test</b>		29/07/2007		<b>Last Inspection</b>				<b>Inspection Interval</b>		52		<b>Next Inspection</b>			
<b>Date of Test</b>	<b>Visual</b>	<b>Earth Bond Current</b>	<b>Earth Bond Resistance</b>	<b>Insulation Resistance</b>	<b>Flash</b>	<b>Load VA</b>	<b>Load A</b>	<b>Leakage</b>	<b>Substitute Leakage</b>	<b>Touch Leakage</b>	<b>Continuity</b>	<b>Result</b>											
29/07/2006	Pass	25.00 A	0.04 OHM	>299.90 MEG		0.71 kVA	2.90 A	0.02 mA	0.00 mA		Pass	Pass											

<b>Appliance Identity</b>		0000000003		<b>Description</b>			VACUUM CLEANER			<b>Location</b>		OFFICE											
<b>Serial Number</b>				<b>Model</b>						<b>Manufacturer</b>													
<b>Date Tested</b>		29/07/2006		<b>Test Interval</b>		52		<b>Next Test</b>		29/07/2007		<b>Last Inspection</b>				<b>Inspection Interval</b>		52		<b>Next Inspection</b>			
<b>Date of Test</b>	<b>Visual</b>	<b>Earth Bond Current</b>	<b>Earth Bond Resistance</b>	<b>Insulation Resistance</b>	<b>Flash</b>	<b>Load VA</b>	<b>Load A</b>	<b>Leakage</b>	<b>Substitute Leakage</b>	<b>Touch Leakage</b>	<b>Continuity</b>	<b>Result</b>											
29/07/2006	Pass	25.00 A	0.05 OHM	>299.90 MEG		0.70 kVA	2.90 A	0.02 mA	0.01 mA		Pass	Pass											

<b>Appliance Identity</b>		0000000004		<b>Description</b>			UPLIGHTER			<b>Location</b>		LOBBY											
<b>Serial Number</b>				<b>Model</b>						<b>Manufacturer</b>													
<b>Date Tested</b>		29/07/2006		<b>Test Interval</b>		52		<b>Next Test</b>		29/07/2007		<b>Last Inspection</b>				<b>Inspection Interval</b>		52		<b>Next Inspection</b>			
<b>Date of Test</b>	<b>Visual</b>	<b>Earth Bond Current</b>	<b>Earth Bond Resistance</b>	<b>Insulation Resistance</b>	<b>Flash</b>	<b>Load VA</b>	<b>Load A</b>	<b>Leakage</b>	<b>Substitute Leakage</b>	<b>Touch Leakage</b>	<b>Continuity</b>	<b>Result</b>											
29/07/2006	Pass	25.00 A	0.05 OHM	>299.90 MEG		0.70 kVA	2.90 A	0.02 mA	0.00 mA		Pass	Pass											

<b>Appliance Identity</b>		0000000005		<b>Description</b>			PROJECTOR			<b>Location</b>		MAIN BUILDING											
<b>Serial Number</b>				<b>Model</b>						<b>Manufacturer</b>													
<b>Date Tested</b>		29/07/2006		<b>Test Interval</b>		52		<b>Next Test</b>		29/07/2007		<b>Last Inspection</b>				<b>Inspection Interval</b>		52		<b>Next Inspection</b>			
<b>Date of Test</b>	<b>Visual</b>	<b>Earth Bond Current</b>	<b>Earth Bond Resistance</b>	<b>Insulation Resistance</b>	<b>Flash</b>	<b>Load VA</b>	<b>Load A</b>	<b>Leakage</b>	<b>Substitute Leakage</b>	<b>Touch Leakage</b>	<b>Continuity</b>	<b>Result</b>											
29/07/2006	Pass	25.00 A	0.04 OHM	>299.90 MEG		0.70 kVA	2.90 A	0.02 mA	0.01 mA		Pass	Pass											

# APPLIANCE PROFILE

Site: Bikes 'R' Us

Reference: BIKES

<b>Appliance Identity</b>		0000000006		<b>Description</b>			TABLE LAMP			<b>Location</b>		OFFICE 1											
<b>Serial Number</b>				<b>Model</b>						<b>Manufacturer</b>													
<b>Date Tested</b>		29/07/2006		<b>Test Interval</b>		52		<b>Next Test</b>		29/07/2007		<b>Last Inspection</b>				<b>Inspection Interval</b>		52		<b>Next Inspection</b>			
<b>Date of Test</b>	<b>Visual</b>	<b>Earth Bond Current</b>	<b>Earth Bond Resistance</b>	<b>Insulation Resistance</b>	<b>Flash</b>	<b>Load VA</b>	<b>Load A</b>	<b>Leakage</b>	<b>Substitute Leakage</b>	<b>Touch Leakage</b>	<b>Continuity</b>	<b>Result</b>											
29/07/2006	Pass			>299.90 MEG		0.00 kVA	0.00 A	0.02 mA	0.00 mA		Pass	Pass											

<b>Appliance Identity</b>		0000000007		<b>Description</b>			RADIO CASSETTE			<b>Location</b>		STAFF ROOM											
<b>Serial Number</b>				<b>Model</b>						<b>Manufacturer</b>													
<b>Date Tested</b>		29/07/2006		<b>Test Interval</b>		52		<b>Next Test</b>		29/07/2007		<b>Last Inspection</b>				<b>Inspection Interval</b>		52		<b>Next Inspection</b>			
<b>Date of Test</b>	<b>Visual</b>	<b>Earth Bond Current</b>	<b>Earth Bond Resistance</b>	<b>Insulation Resistance</b>	<b>Flash</b>	<b>Load VA</b>	<b>Load A</b>	<b>Leakage</b>	<b>Substitute Leakage</b>	<b>Touch Leakage</b>	<b>Continuity</b>	<b>Result</b>											
29/07/2006	Pass			>299.90 MEG		0.00 kVA	0.00 A	0.02 mA	0.00 mA		Pass	Pass											

<b>Appliance Identity</b>		0000000008		<b>Description</b>			CALCULATOR			<b>Location</b>		FINANCE DEPARTMENT											
<b>Serial Number</b>				<b>Model</b>						<b>Manufacturer</b>													
<b>Date Tested</b>		29/07/2006		<b>Test Interval</b>		52		<b>Next Test</b>		29/07/2007		<b>Last Inspection</b>				<b>Inspection Interval</b>		52		<b>Next Inspection</b>			
<b>Date of Test</b>	<b>Visual</b>	<b>Earth Bond Current</b>	<b>Earth Bond Resistance</b>	<b>Insulation Resistance</b>	<b>Flash</b>	<b>Load VA</b>	<b>Load A</b>	<b>Leakage</b>	<b>Substitute Leakage</b>	<b>Touch Leakage</b>	<b>Continuity</b>	<b>Result</b>											
29/07/2006	Pass			>299.90 MEG		0.00 kVA	0.00 A	0.02 mA	0.00 mA		Pass	Pass											

<b>Appliance Identity</b>		0000000009		<b>Description</b>			PC			<b>Location</b>		FINANCE DEPARTMENT											
<b>Serial Number</b>				<b>Model</b>						<b>Manufacturer</b>													
<b>Date Tested</b>		29/07/2006		<b>Test Interval</b>		52		<b>Next Test</b>		29/07/2007		<b>Last Inspection</b>				<b>Inspection Interval</b>		52		<b>Next Inspection</b>			
<b>Date of Test</b>	<b>Visual</b>	<b>Earth Bond Current</b>	<b>Earth Bond Resistance</b>	<b>Insulation Resistance</b>	<b>Flash</b>	<b>Load VA</b>	<b>Load A</b>	<b>Leakage</b>	<b>Substitute Leakage</b>	<b>Touch Leakage</b>	<b>Continuity</b>	<b>Result</b>											
29/07/2006	Pass					0.00 kVA	0.00 A	0.01 mA	0.00 mA	0.00 mA	Pass	Pass											

<b>Appliance Identity</b>		0000000010		<b>Description</b>			PRINTER			<b>Location</b>		FINANCE DEPARTMENT											
<b>Serial Number</b>				<b>Model</b>						<b>Manufacturer</b>													
<b>Date Tested</b>		29/07/2006		<b>Test Interval</b>		52		<b>Next Test</b>		29/07/2007		<b>Last Inspection</b>				<b>Inspection Interval</b>		52		<b>Next Inspection</b>			
<b>Date of Test</b>	<b>Visual</b>	<b>Earth Bond Current</b>	<b>Earth Bond Resistance</b>	<b>Insulation Resistance</b>	<b>Flash</b>	<b>Load VA</b>	<b>Load A</b>	<b>Leakage</b>	<b>Substitute Leakage</b>	<b>Touch Leakage</b>	<b>Continuity</b>	<b>Result</b>											
29/07/2006	Pass					0.00 kVA	0.00 A	0.02 mA	0.00 mA	0.00 mA	Pass	Pass											